



**HERMON LABORATORIES**



**Certificate of Conformity**  
**with EMC Directive 2004/108/EC, Article 5;**  
**FCC 47CFR part 15 subpart B**

**N° APMEMC\_19611C**

Product definition ..... : 3DLevelScanner II  
Product types ..... : S, M, MV with Controller Card Type ATEX  
Applicant / Manufacturer ..... : APM Automation Solutions Ltd.  
Address ..... : 24 Habarzel Street, Tel Aviv 69710, Israel  
Telephone number ..... : +972 3648 8891  
Fax number ..... : +972 3648 8892

This Certificate of Conformity has been granted to the applicant based on the results of tests and measurements, performed by Hermon Laboratories on a sample of the above-mentioned product from April 20 to July 5, 2009.

The tested product satisfies the requirements of:  
EN 61326-1:2006 standard, harmonized under EMC Directive 2004/108/EC Article 6(2), for equipment intended for use in industrial locations, complies with class A limits for radiated emissions;  
FCC 47 CFR part 15:2008, subpart B, class A.

Measurements/tests results are contained in the test report:  
APMEMC\_19611.

**Michael Nikishin, EMC and Radio Group Leader**  
**Hermon Laboratories Ltd.**

September 3, 2009

---

The comments in the associated (if applicable) test report/s shall be taken into account and used in conjunction with this certificate. The "A2LA Accredited" symbol endorsement applies only to the tests and calibrations that are listed in the scope of Hermon Laboratories accreditation.